

## School Environmental Inspection Summary For 2007 - 2008

**School Name:** Edwards Middle School  
**Address:** 28 Walker Street, Charlestown, MA 02129  
**Date of inspection:** 12/27/2007  
**Inspector(s):** Heather Strauss  
**Has Written IPM Program in Office:** Y  
**Date of Last IPM Activity Logged:** 12/5/2007  
**Number of areas:** 65  
**Number of areas inspected:** 57  
**Source of Drinking Water:** Bottled Water

Environmental Issue	Number of areas with the Condition	Percentage of areas inspected with the condition
Leaks/Water Stains	3	5.2%
Visible Mold Growth	0	0.0%
Overt Pest Sign	0	0.0%
Clutter	3	5.2%
Dust	0	0.0%
Cleaning needed	0	0.0%
Repairs needed	15	25.9%
Improper Chemical Storage	0	0.0%

	Normal Indoor Range	Average outside the school	Average inside the school
CO <sub>2</sub> level	375 – 1,000 ppm	450	479
CO level	0 - 9 ppm	0	0
PM <sub>10</sub> (airborne dust) level	0.00 - .05 mg/m <sup>3</sup>	0.031	0.02
VOC level	150 – 300 ppb	0	0
Temperature	68 – 75 degrees	36	61.1

<b>Bathrooms: Items/Conditions</b>	
Number of bathrooms inspected:	6
Total number of urinals	16
Number of non-functioning urinals	0
Total number of toilets	33
Number of non-functioning toilets	0
Number with bad stall doors	0
Number of toilets without toilet paper	0
Number of bathroom sinks	17
Number of broken sinks	0
Number of soap dispensers	
Number of broken dispensers	0
Percent of bathrooms without adequate soap	0.0%
Percent of bathrooms without paper towels	0.0%

