

School Environmental Inspection Summary For 2007 - 2008

School Name: Lilla G. Frederick Pilot Middle School
Address: 270 Columbia Rd, Dorchester, MA 02121
Date of inspection: 2/5/2008
Inspector(s): Maria Carvalho
Has Written IPM Program in Office: Y
Date of Last IPM Activity Logged: 1/10/2008
Number of areas: 87
Number of areas inspected: 84
Source of Drinking Water

Environmental Issue	Number of areas with the Condition	Percentage of areas inspected with the condition
Leaks/Water Stains	1	1.2%
Visible Mold Growth	0	0.0%
Overt Pest Sign	1	1.2%
Clutter	0	0.0%
Dust	0	0.0%
Cleaning needed	0	0.0%
Repairs needed	0	0.0%
Improper Chemical Storage	0	0.0%

	Normal Indoor Range	Average outside the school	Average inside the school
CO ₂ level	375 – 1,000 ppm	350	622
CO level	0 - 9 ppm	0	0
PM ₁₀ (airborne dust) level	0.00 - .05 mg/m ³	0.012	0.016
VOC level	150 – 300 ppb	0	0
Temperature	68 – 75 degrees	45	71.4

Bathrooms: Items/Conditions	
Number of bathrooms inspected:	15
Total number of urinals	8
Number of non-functioning urinals	0
Total number of toilets	33
Number of non-functioning toilets	0
Number with bad stall doors	1
Number of toilets without toilet paper	29
Number of bathroom sinks	30
Number of broken sinks	0
Number of soap dispensers	16
Number of broken dispensers	0
Percent of bathrooms without adequate soap	6.7%
Percent of bathrooms without paper towels	0.0%

