

School Environmental Inspection Summary For 2007 - 2008

School Name: Haley Elementary School
Address: 570 American Legion Highway, Rosindale 02131
Date of inspection: 11/26/2007
Inspector(s): Jeff Lane
Has Written IPM Program in Office: Y
Date of Last IPM Activity Logged: 10/23/2007
Number of areas: 42
Number of areas inspected: 41
Source of Drinking Water: City Water

Environmental Issue	Number of areas with the Condition	Percentage of areas inspected with the condition
Leaks/Water Stains	9	20.5%
Visible Mold Growth	0	0.0%
Overt Pest Sign	0	0.0%
Clutter	3	6.8%
Dust	2	4.5%
Cleaning needed	0	0.0%
Repairs needed	15	34.1%
Improper Chemical Storage	0	0.0%

	Normal Indoor Range	Average outside the school	Average inside the school
CO ₂ level	375 – 1,000 ppm	440	624
CO level	0 - 9 ppm	0.2	0.4
PM ₁₀ (airborne dust) level	0.00 - .05 mg/m ³	0.036	0.023
VOC level	150 – 300 ppb		
Temperature	68 – 75 degrees	44.9	70

Bathrooms: Items/Conditions	
Number of bathrooms inspected:	9
Total number of urinals	5
Number of non-functioning urinals	0
Total number of toilets	15
Number of non-functioning toilets	1
Number with bad stall doors	1
Number of toilets without toilet paper	0
Number of bathroom sinks	14
Number of broken sinks	0
Number of soap dispensers	7
Number of broken dispensers	0
Percent of bathrooms without adequate soap	44.4%
Percent of bathrooms without paper towels	0.0%

