

School Environmental Inspection Summary For 2007 - 2008

School Name: Hurley School (K-8)
Address: 70 Worcester Street, Boston, MA 02130
Date of inspection: 12/27/2007
Inspector(s): Maria Carvalho
Has Written IPM Program in Office:
Date of Last IPM Activity Logged:
Number of areas: 26
Number of areas inspected: 26
Source of Drinking Water: Bottled Water

Environmental Issue	Number of areas with the Condition	Percentage of areas inspected with the condition
Leaks/Water Stains	0	0.0%
Visible Mold Growth	0	0.0%
Overt Pest Sign	1	3.7%
Clutter	0	0.0%
Dust	0	0.0%
Cleaning needed	0	0.0%
Repairs needed	0	0.0%
Improper Chemical Storage	0	0.0%

	Normal Indoor Range	Average outside the school	Average inside the school
CO ₂ level	375 – 1,000 ppm		552
CO level	0 - 9 ppm		0
PM ₁₀ (airborne dust) level	0.00 - .05 mg/m ³		0.019
VOC level	150 – 300 ppb		0
Temperature	68 – 75 degrees		67.4

Bathrooms: Items/Conditions	
Number of bathrooms inspected:	5
Total number of urinals	14
Number of non-functioning urinals	0
Total number of toilets	25
Number of non-functioning toilets	0
Number with bad stall doors	0
Number of toilets without toilet paper	25
Number of bathroom sinks	17
Number of broken sinks	1
Number of soap dispensers	13
Number of broken dispensers	0
Percent of bathrooms without adequate soap	0.0%
Percent of bathrooms without paper towels	0.0%

