

School Environmental Inspection Summary For 2007 - 2008

School Name: James M. Curley Elementary School
Address: 40 Pershing Road, Jamiaca Plain, MA 02130
Date of inspection: 1/16/2008
Inspector(s): Michael DiLorenzo
Has Written IPM Program in Office: Y
Date of Last IPM Activity Logged: 12/13/2007
Number of areas: 25
Number of areas inspected: 23
Source of Drinking Water: City Water

Environmental Issue	Number of areas with the Condition	Percentage of areas inspected with the condition
Leaks/Water Stains	1	4.3%
Visible Mold Growth	0	0.0%
Overt Pest Sign	3	13.0%
Clutter	2	8.7%
Dust	0	0.0%
Cleaning needed	0	0.0%
Repairs needed	5	21.7%
Improper Chemical Storage	1	4.3%

	Normal Indoor Range	Average outside the school	Average inside the school
CO ₂ level	375 – 1,000 ppm		1035
CO level	0 - 9 ppm		0
PM ₁₀ (airborne dust) level	0.00 - .05 mg/m ³		0.026
VOC level	150 – 300 ppb		0
Temperature	68 – 75 degrees		71

Bathrooms: Items/Conditions	
Number of bathrooms inspected:	9
Total number of urinals	5
Number of non-functioning urinals	0
Total number of toilets	15
Number of non-functioning toilets	0
Number with bad stall doors	0
Number of toilets without toilet paper	15
Number of bathroom sinks	11
Number of broken sinks	0
Number of soap dispensers	11
Number of broken dispensers	0
Percent of bathrooms without adequate soap	0.0%
Percent of bathrooms without paper towels	0.0%

