

School Environmental Inspection Summary For 2007 - 2008

School Name: Lee Elementary School
Address: 155 Talbot Avenue, Dorchester 02124
Date of inspection: 2/15/2008
Inspector(s): Jeff Lane
Has Written IPM Program in Office: Y
Date of Last IPM Activity Logged: 12/27/2007
Number of areas: 165
Number of areas inspected: 146
Source of Drinking Water: Bottled Water

Environmental Issue	Number of areas with the Condition	Percentage of areas inspected with the condition
Leaks/Water Stains	16	10.8%
Visible Mold Growth	1	0.7%
Overt Pest Sign	10	6.8%
Clutter	8	5.4%
Dust	14	9.5%
Cleaning needed	14	9.5%
Repairs needed	56	37.8%
Improper Chemical Storage	2	1.4%

	Normal Indoor Range	Average outside the school	Average inside the school
CO ₂ level	375 – 1,000 ppm	371	663
CO level	0 - 9 ppm	0.2	0
PM ₁₀ (airborne dust) level	0.00 - .05 mg/m ³		
VOC level	150 – 300 ppb		0
Temperature	68 – 75 degrees	39.1	73

Bathrooms: Items/Conditions	
Number of bathrooms inspected:	46
Total number of urinals	20
Number of non-functioning urinals	2
Total number of toilets	70
Number of non-functioning toilets	0
Number with bad stall doors	0
Number of toilets without toilet paper	0
Number of bathroom sinks	70
Number of broken sinks	2
Number of soap dispensers	65
Number of broken dispensers	2
Percent of bathrooms without adequate soap	0.0%
Percent of bathrooms without paper towels	0.0%

