

School Environmental Inspection Summary For 2007 - 2008

School Name: Marshall Elementary School
Address: 35 Westville Street, Dorchester, MA 02124
Date of inspection: 1/14/2008
Inspector(s): Maria Carvalho
Has Written IPM Program in Office:
Date of Last IPM Activity Logged:
Number of areas: 106
Number of areas inspected: 99
Source of Drinking Water: Bottled Water

Environmental Issue	Number of areas with the Condition	Percentage of areas inspected with the condition
Leaks/Water Stains	0	0.0%
Visible Mold Growth	0	0.0%
Overt Pest Sign	0	0.0%
Clutter	2	2.0%
Dust	0	0.0%
Cleaning needed	2	2.0%
Repairs needed	0	0.0%
Improper Chemical Storage	0	0.0%

	Normal Indoor Range	Average outside the school	Average inside the school
CO ₂ level	375 – 1,000 ppm	375	510
CO level	0 - 9 ppm	0	0
PM ₁₀ (airborne dust) level	0.00 - .05 mg/m ³	0.021	0.019
VOC level	150 – 300 ppb	0	0
Temperature	68 – 75 degrees	35	66.2

Bathrooms: Items/Conditions	
Number of bathrooms inspected:	30
Total number of urinals	13
Number of non-functioning urinals	0
Total number of toilets	62
Number of non-functioning toilets	1
Number with bad stall doors	2
Number of toilets without toilet paper	52
Number of bathroom sinks	59
Number of broken sinks	0
Number of soap dispensers	48
Number of broken dispensers	0
Percent of bathrooms without adequate soap	6.7%
Percent of bathrooms without paper towels	10.0%

