

## School Environmental Inspection Summary For 2007 - 2008

**School Name:** O'Hearn Elementary School  
**Address:** 1669 Dorchester Avenue, Dorchester, MA 02122  
**Date of inspection:** 12/5/2007  
**Inspector(s):** Jeff Lane  
**Has Written IPM Program in Office:** Y  
**Date of Last IPM Activity Logged:** 11/26/2007  
**Number of areas:** 39  
**Number of areas inspected:** 38  
**Source of Drinking Water:** Bottled Water

Environmental Issue	Number of areas with the Condition	Percentage of areas inspected with the condition
Leaks/Water Stains	7	17.5%
Visible Mold Growth	0	0.0%
Overt Pest Sign	1	2.5%
Clutter	3	7.5%
Dust	4	10.0%
Cleaning needed	2	5.0%
Repairs needed	17	42.5%
Improper Chemical Storage	0	0.0%

	Normal Indoor Range	Average outside the school	Average inside the school
CO <sub>2</sub> level	375 – 1,000 ppm	458	929
CO level	0 - 9 ppm	0.1	0
PM <sub>10</sub> (airborne dust) level	0.00 - .05 mg/m <sup>3</sup>		
VOC level	150 – 300 ppb		
Temperature	68 – 75 degrees	37.7	72.5

Bathrooms: Items/Conditions	
Number of bathrooms inspected:	12
Total number of urinals	10
Number of non-functioning urinals	0
Total number of toilets	20
Number of non-functioning toilets	1
Number with bad stall doors	0
Number of toilets without toilet paper	0
Number of bathroom sinks	19
Number of broken sinks	0
Number of soap dispensers	15
Number of broken dispensers	0
Percent of bathrooms without adequate soap	0.0%
Percent of bathrooms without paper towels	0.0%

