

School Environmental Inspection Summary For 2007 - 2008

School Name: Tobin School (K-8)
Address: 40 Smith Street, Roxbury, MA 02120
Date of inspection: 1/9/2008
Inspector(s): Heather Strauss
Has Written IPM Program in Office: Y
Date of Last IPM Activity Logged: 12/10/2007
Number of areas: 50
Number of areas inspected: 45
Source of Drinking Water: Bottled Water

Environmental Issue	Number of areas with the Condition	Percentage of areas inspected with the condition
Leaks/Water Stains	6	13.0%
Visible Mold Growth	0	0.0%
Overt Pest Sign	0	0.0%
Clutter	2	4.3%
Dust	0	0.0%
Cleaning needed	1	2.2%
Repairs needed	34	73.9%
Improper Chemical Storage	0	0.0%

	Normal Indoor Range	Average outside the school	Average inside the school
CO ₂ level	375 – 1,000 ppm	410	547
CO level	0 - 9 ppm	0	0
PM ₁₀ (airborne dust) level	0.00 - .05 mg/m ³	0.013	0.019
VOC level	150 – 300 ppb	0	0
Temperature	68 – 75 degrees	60.2	72.3

Bathrooms: Items/Conditions	
Number of bathrooms inspected:	9
Total number of urinals	15
Number of non-functioning urinals	2
Total number of toilets	39
Number of non-functioning toilets	0
Number with bad stall doors	11
Number of toilets without toilet paper	9
Number of bathroom sinks	20
Number of broken sinks	7
Number of soap dispensers	18
Number of broken dispensers	0
Percent of bathrooms without adequate soap	55.6%
Percent of bathrooms without paper towels	11.1%

