

School Environmental Inspection Summary For 2007 - 2008

School Name: Warren/Prescott Elementary School
Address: 50 School Street, Charlestown, MA 02129
Date of inspection: 12/27/2007
Inspector(s): Heather Strauss
Has Written IPM Program in Office: Y
Date of Last IPM Activity Logged: 12/1/2006
Number of areas: 44
Number of areas inspected: 40
Source of Drinking Water: Bottled Water

| Environmental Issue | Number of areas with the Condition | Percentage of areas inspected with the condition |
|---------------------------|------------------------------------|--|
| Leaks/Water Stains | 4 | 9.8% |
| Visible Mold Growth | 0 | 0.0% |
| Overt Pest Sign | 0 | 0.0% |
| Clutter | 3 | 7.3% |
| Dust | 0 | 0.0% |
| Cleaning needed | 0 | 0.0% |
| Repairs needed | 8 | 19.5% |
| Improper Chemical Storage | 0 | 0.0% |

| | Normal Indoor Range | Average outside the school | Average inside the school |
|--|------------------------------|----------------------------|---------------------------|
| CO ₂ level | 375 – 1,000 ppm | 400 | 476 |
| CO level | 0 - 9 ppm | 0 | 0 |
| PM ₁₀ (airborne dust) level | 0.00 - .05 mg/m ³ | 0.008 | 0.014 |
| VOC level | 150 – 300 ppb | 0 | 0 |
| Temperature | 68 – 75 degrees | 39.7 | 67.5 |

| Bathrooms: Items/Conditions | |
|--|-------|
| Number of bathrooms inspected: | 9 |
| Total number of urinals | 19 |
| Number of non-functioning urinals | 0 |
| Total number of toilets | 42 |
| Number of non-functioning toilets | 0 |
| Number with bad stall doors | 0 |
| Number of toilets without toilet paper | 0 |
| Number of bathroom sinks | 23 |
| Number of broken sinks | 0 |
| Number of soap dispensers | 23 |
| Number of broken dispensers | 1 |
| Percent of bathrooms without adequate soap | 11.1% |
| Percent of bathrooms without paper towels | 0.0% |

